

IEC 61850 Certificate - IEC 61850 Certificate #1933

iBC 5000 (Elitel 5/5000) [ELIOP S.A.]

07/08/2021 04:19 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30710139-Consulting 08-0041
61850 Edition:	Edition 1	Certificate Hash:	521C465979BB62D2F7145FA1B1D059 D1AB13CA58601F8613118EB3A85D35 ED22
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ELIOP S.A.	Vendor Artifact Hash:	
Address:	Pol. Ind. Alcobendas Avda. Valgrande, 8 28108 Madrid Spain	Umbrella Organization:	
Product:	iBC 5000 (Elitel 5/5000)	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.09/Review 5	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	06/27/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:19 PM - Herbert Falk

- File 08-0041-ELIOP-ELITEL5-Certificate.pdf added

Files

08-0041-ELIOP-ELITEL5-Certificate.pdf	294 KB	07/08/2021	Herbert Falk
---------------------------------------	--------	------------	--------------