

IEC 61850 Certificate - IEC 61850 Certificate #1936

CSC-101 Numerical Transmission [Beijing Sifang Automation Co., Ltd.]

07/08/2021 04:19 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30720560-Consulting 08-0201
61850 Edition:	Edition 1	Certificate Hash:	59BFA6A07A94046B72312D81B8A6111 CD3B4E79CC613D5A79003A0302724D 65D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Beijing Sifang Automation Co., Ltd.	Vendor Artifact Hash:	
Address:	Beijing Sifang Engineering CO., LTD No. 9, Shangdi 4th Street, Haidian District Beijing, P.R.C 100085	Umbrella Organization:	
Product:	CSC-101 Numerical Transmission	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.10	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Direct Control (12a), Enhanced SBO Control (12d), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/27/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:19 PM - Herbert Falk

- File 08-0201_SiFang-CSC101-Certificate.pdf added

Files

08-0201_SiFang-CSC101-Certificate.pdf	714 KB	07/08/2021	Herbert Falk
---------------------------------------	--------	------------	--------------