

IEC 61850 Certificate - IEC 61850 Certificate #1946

#ZLV-B [ZIV GRID Automation S.L.]

07/08/2021 04:19 PM - Herbert Falk

| | | | |
|-------------------------------------|--|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 30720620-Consulting 08-0560 |
| 61850 Edition: | Edition 1 | Certificate Hash: | 1E6698AA05EBCECC0B1F3222494A02 00CA47C49FD86AF32C100BB9AB1D6 9A0E4 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | ZIV GRID Automation S.L. | Vendor Artifact Hash: | |
| Address: | Parque Tecnológico, 210 48170 Zamudio Spain | Umbrella Organization: | |
| Product: | #ZLV-B | Optional Reservation Test: | No |
| HW Version: | OS 2.0 | Serial Number: | |
| SW Version: | 4.6 | Publisher Legacy Variants: | |
| Key Words: | | Publisher Preferred Rates: | |
| Test Procedure Version: | 1.1 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | rebecca.davenport,bruce.muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 07/01/2015 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | ABB Switzerland Ltd. (B) | | |

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:19 PM - Herbert Falk

- File 08-0560_CertificateZIV_ZLVB.pdf added

Files

| | | | |
|---------------------------------|---------|------------|--------------|
| 08-0560_CertificateZIV_ZLVB.pdf | 1010 KB | 07/08/2021 | Herbert Falk |
|---------------------------------|---------|------------|--------------|