

IEC 61850 Certificate - IEC 61850 Certificate #1948

G1IF4 [TOSHIBA Corporation]

07/08/2021 04:19 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30820075-Consulting 08-0632
61850 Edition:	Edition 1	Certificate Hash:	8A10000524E2BEF23DE754431B71273 2217DFC44085B0E55CCA77C0DEC3F 9916
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	TOSHIBA Corporation	Vendor Artifact Hash:	
Address:	Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-Shi, Toyko, 183-8511 Japan	Umbrella Organization:	
Product:	G1IF4	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	GPM850-03-B	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/03/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:19 PM - Herbert Falk

- File 08-0632-G1IF4-Certificate.pdf added

Files

08-0632-G1IF4-Certificate.pdf	1.29 MB	07/08/2021	Herbert Falk
-------------------------------	---------	------------	--------------