

IEC 61850 Certificate - IEC 61850 Certificate #1952

D25 Multifunctional IED [GE Energy]

07/08/2021 04:19 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30720517-Consulting 08-1041
61850 Edition:	Edition 1	Certificate Hash:	9FF6C4049412A8C828E9756828E1FD7 A3059958A61F644F2A08BB559FBD1F 39C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Energy	Vendor Artifact Hash:	
Address:	2728 Hopewell Place NE, Calgary, AB T1Y 7J7 Canada	Umbrella Organization:	
Product:	D25 Multifunctional IED	Optional Reservation Test:	No
HW Version:	Gen 4	Serial Number:	
SW Version:	240	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/03/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:19 PM - Herbert Falk

- File 08-1041-D25-Certificate.pdf added

Files

08-1041-D25-Certificate.pdf

734 KB

07/08/2021

Herbert Falk