

IEC 61850 Certificate - IEC 61850 Certificate #1955

SEL-710 Motor Protection Relay [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:19 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30820049-Consulting 08-1220
61850 Edition:	Edition 1	Certificate Hash:	12145CB0754B34190DC706BD01A6EB 0A7B4C37620F14AFDCD7706E4B7B19 C9EE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2440 N.E. Hopkins Ct. Pullman, WA 99163 USA	Umbrella Organization:	
Product:	SEL-710 Motor Protection Relay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R204	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/03/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	ABB Switzerland Ltd. (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:19 PM - Herbert Falk

- File 08-1220-SEL710-Certificate.pdf added

Files

08-1220-SEL710-Certificate.pdf	420 KB	07/08/2021	Herbert Falk
--------------------------------	--------	------------	--------------