

IEC 61850 Certificate - IEC 61850 Certificate #1957

REM 545 w/SPA-ZC 400 [ABB Oy]

07/08/2021 04:19 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30810022-Consulting 08-1271
61850 Edition:	Edition 1	Certificate Hash:	46F3B7C509DF4F85FD014D6002BC82 42A0D2282CB027D28BDA74A2AC1031 6F71
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB Oy	Vendor Artifact Hash:	
Address:	Distribution Automation Muottitie 2 A FI-65101 Vaasa Finland	Umbrella Organization:	
Product:	REM 545 w/SPA-ZC 400	Optional Reservation Test:	No
HW Version:	2.5	Serial Number:	
SW Version:	2.1.2	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/03/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:19 PM - Herbert Falk

- File 08-1271-ABB-REM545-Certificate.pdf added

Files

08-1271-ABB-REM545-Certificate.pdf

707 KB

07/08/2021

Herbert Falk