IEC 61850 Certificate - IEC 61850 Certificate #1958

RET 545 w/SPA-ZC 400 [ABB Oy]

07/08/2021 04:19 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30810022-Consulting 08-1273
61850 Tested Aspects:	Server	**Certificate Hash:**	6656A7F58BC1419DBC90CAF8C4E65058B952354555648B912CE26D0F91A5281E
Company:	ABB Oy	**Vendor Artifact File Name:**	
Address:	Distribution Automation Muottitie 2 A FI-65101 Vaasa Finland	**Vendor Artifact Hash:**	
Product:	RET 545 w/SPA-ZC 400	**Umbrella Organization:**	
HW Version:	3.0	**Optional Reservation Test:**	No
SW Version:	2.1.2	**Serial Number:**	
Key Words:		**Publisher Legacy Variants:**	
Test Procedure Version:	1.1	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	07/03/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-1273-ABB-RET545-Certificate.pdf added

Files

08-1273-ABB-RET545-Certificate.pdf	751 KB	07/08/2021	Herbert Falk