

IEC 61850 Certificate - IEC 61850 Certificate #1958

RET 545 w/SPA-ZC 400 [ABB Oy]

07/08/2021 04:19 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30810022-Consulting 08-1273
61850 Edition:	Edition 1	Certificate Hash:	6656A7F58BC1419DBC90CAF8C4E650 58B952354555648B912CE26D0F91A52 81E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB Oy	Vendor Artifact Hash:	
Address:	Distribution Automation Muottitie 2 A FI-65101 Vaasa Finland	Umbrella Organization:	
Product:	RET 545 w/SPA-ZC 400	Optional Reservation Test:	No
HW Version:	3.0	Serial Number:	
SW Version:	2.1.2	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/03/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-1273-ABB-RET545-Certificate.pdf added

Files

08-1273-ABB-RET545-Certificate.pdf

751 KB

07/08/2021

Herbert Falk