

IEC 61850 Certificate - IEC 61850 Certificate #1961

RCS-9611C [NARI-RELAYS]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30820176-Consulting 08-1721
61850 Edition:	Edition 1	Certificate Hash:	9F851534CA9F221DB14AB530750C2E 7C3900DDFF272B956BC7B0F1AB70C C7891
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NARI-RELAYS	Vendor Artifact Hash:	
Address:	69 Suyuan Road Jiangning Nanjing 211102 P.R. of China	Umbrella Organization:	
Product:	RCS-9611C	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R2.20	Publisher Legacy Variants:	
Key Words:	Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/04/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-1721_NARI_Relays_RCS-9611_Certificate.pdf added

Files

08-1721_NARI_Relays_RCS-9611_Certificate.pdf	544 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------