

IEC 61850 Certificate - IEC 61850 Certificate #1962

TM1703 ACP [Siemens AG Osterreich]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30720572-Consulting 08-1736
61850 Edition:	Edition 1	Certificate Hash:	B2D20F12ECF001618C38F6068B4E21 AC3FCA16A46C3901FDF63E9B1BE11 F0B6F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens AG Osterreich	Vendor Artifact Hash:	
Address:	Ruthnergasse 3 A-1210 Vienna Austria	Umbrella Organization:	
Product:	TM1703 ACP	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:		Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/14/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-1736_SJM_SICAM1703TM-Certificate.pdf added

#2 - 07/10/2021 08:23 PM - Herbert Falk

- Address updated

- Approval Date changed from 07/04/2015 to 07/14/2015

Files

08-1736_SJM_SICAM1703TM-Certificate.pdf	468 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------