

IEC 61850 Certificate - IEC 61850 Certificate #1968

IED 670 1.1r10 [ABB AB]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30710115-Consulting 08-2148
61850 Edition:	Edition 1	Certificate Hash:	FD487019D50EB00677D82774A6E544 DA73E5061F719163BE14DF7E942400 C904
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB AB	Vendor Artifact Hash:	
Address:	SA Products S-721 59 Vasteras Sweden	Umbrella Organization:	
Product:	IED 670 1.1r10	Optional Reservation Test:	No
HW Version:	1MRK001535-14	Serial Number:	
SW Version:	1.4_77m_19	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/04/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-2148_ABB_IED670-Certificate.pdf added

Files

08-2148_ABB_IED670-Certificate.pdf

458 KB

07/08/2021

Herbert Falk