IEC 61850 Certificate - IEC 61850 Certificate #1968

IED 670 1.1r10 [ABB AB]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30710115-Consulting 08-2148
61850 Tested Aspects:	Server	**Certificate Hash:**	FD487019D50EB00677D82774A6E544DA73E5061F719163BE14DF7E942400C904
Company:	ABB AB	**Vendor Artifact File Name:**	
Address:	SA Products S-721 59 Vasteras Sweden	**Vendor Artifact Hash:**	
Product:	IED 670 1.1r10	**Umbrella Organization:**	
HW Version:	1MRK001535-14	**Optional Reservation Test:**	No
SW Version:	1.4_77m_19	**Serial Number:**	
Key Words:		**Publisher Legacy Variants:**	
Test Procedure Version:	1.1	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	07/04/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-2148_ABB_IED670-Certificate.pdf added

Files

08-2148_ABB_IED670-Certificate.pdf	458 KB	07/08/2021	Herbert Falk