

IEC 61850 Certificate - IEC 61850 Certificate #1969

Areva MiCOM P746 [Areva T&D]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30820213-Consulting 08-2150
61850 Edition:	Edition 1	Certificate Hash:	CE5A7AED4359B5A92AD9D0770E4587 323C38F1DAA2B80D8B285AFBDDC0B FFA65
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Areva T&D	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford ST17 4LX United Kingdom	Umbrella Organization:	
Product:	Areva MiCOM P746	Optional Reservation Test:	No
HW Version:	K	Serial Number:	
SW Version:	01A	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/04/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-2150_Areva_P746-Certificate.pdf added

Files

08-2150_Areva_P746-Certificate.pdf

460 KB

07/08/2021

Herbert Falk