

IEC 61850 Certificate - IEC 61850 Certificate #1971

MR4010E Bay Control and Monito [Mitsubishi Electric Corporation]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30820191-Consulting 08-2413
61850 Edition:	Edition 1	Certificate Hash:	6842D47AAEB1F836A50F2EF2C87918 43F222D1A7A36840AC806A93FE46656 BBA
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	Protection & Control Systems Transmission & Distribution Systems Center Kobe, Japan	Umbrella Organization:	
Product:	MR4010E Bay Control and Monito	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	com506_00000005	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Time Synchronization (B13)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/04/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-2413-Mitsubishi-MR4010-Certificate.pdf added

Files

08-2413-Mitsubishi-MR4010-Certificate.pdf	735 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------