

IEC 61850 Certificate - IEC 61850 Certificate #1972

T-LU Local Unit for Transforme [HYOSUNG Corporation]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30820245-Consulting 08-2690
61850 Edition:	Edition 1	Certificate Hash:	69B14EADA869EA57FB7683629D2885 065CD2C16262FF1417FB4050FD4F52 04FE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	HYOSUNG Corporation	Vendor Artifact Hash:	
Address:	454-2 Nae-Dong Changwon Korea (641-712)	Umbrella Organization:	
Product:	T-LU Local Unit for Transforme	Optional Reservation Test:	No
HW Version:	1.0	Serial Number:	
SW Version:	3.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 08-2690-Hyosung-TLU-Certificate.pdf added

Files

08-2690-Hyosung-TLU-Certificate.pdf	936 KB	07/08/2021	Herbert Falk
-------------------------------------	--------	------------	--------------