

IEC 61850 Certificate - IEC 61850 Certificate #1975

AREVA P632 [Areva T&D]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920191-Consulting 09-0562
61850 Edition:	Edition 1	Certificate Hash:	19D05DF3991B82D5513928FB2F594E6 9B2110480DE1D1F8DC1406BFD05AB4 F17
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Areva T&D	Vendor Artifact Hash:	
Address:	Lyoner Strasse 44-48 D-60528 Frankfurt am Main Germany	Umbrella Organization:	Schneider Electric
Product:	AREVA P632	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	611-204	Publisher Legacy Variants:	
Key Words:	Differential, Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 09-0562-AREVA-P632-Certificate.pdf added

#2 - 07/09/2021 09:15 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

09-0562-AREVA-P632-Certificate.pdf	650 KB	07/08/2021	Herbert Falk
------------------------------------	--------	------------	--------------