

# IEC 61850 Certificate - IEC 61850 Certificate #1976

## AREVA MiCOM P143 [Areva T&D UK Ltd.]

07/08/2021 04:20 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30920191-Consulting 09-0564
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	C9934D77435F376B7DC0E0363746F62 A30E6209E31C9FF81FF5E0373D65A6 1CF
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Areva T&D UK Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	St. Leonards Avenue ST174LX ENGLAND	<b>Umbrella Organization:</b>	
<b>Product:</b>	AREVA MiCOM P143	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	42C	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/05/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 09-0564-AREVA-P143-Certificate.pdf added

### Files

09-0564-AREVA-P143-Certificate.pdf	692 KB	07/08/2021	Herbert Falk
------------------------------------	--------	------------	--------------