

IEC 61850 Certificate - IEC 61850 Certificate #1977

AREVA MiCOM P141 [Areva T&D UK Ltd.]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920191-Consulting 09-0566
61850 Edition:	Edition 1	Certificate Hash:	817899E7833AE6B7E243C420F8E425F BEA65DACEFDCCCD1F36F1159EBC7 F4D40
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Areva T&D UK Ltd.	Vendor Artifact Hash:	
Address:	St. Leonards Avenue ST174LX ENGLAND	Umbrella Organization:	
Product:	AREVA MiCOM P141	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	42C	Publisher Legacy Variants:	
Key Words:	Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/05/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 09-0566-AREVA-P141-Certificate.pdf added

Files

09-0566-AREVA-P141-Certificate.pdf

626 KB

07/08/2021

Herbert Falk