

IEC 61850 Certificate - IEC 61850 Certificate #1978

FeederVision FVD [P&B Engineering]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Test Document:
61850 Tested Aspects:	Server	Certificate Name: 30820234-Consulting 09-0762
Company:	P&B Engineering	Certificate Hash: 1574E93D453BA625EB983E62CE296A264BF203E725F358987B2D0B3002858993
Address:	Belle Vue Works Boundary Street Manchester M12 5NG UK	Vendor Artifact File Name:
Product:	FeederVision FVD	Vendor Artifact Hash:
HW Version:		Umbrella Organization:
SW Version:	2.022	Optional Reservation Test: No
Key Words:	Protection, Relay	Serial Number:
Test Procedure Version:	2.2	Publisher Legacy Variants:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Rates:
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Publisher Preferred Variants:
Approval Date:	07/06/2015	Subscriber Legacy Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Variants:
Current Test Lab Name:	DNV Netherlands (A)	Subscriber Preferred Rates:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:20 PM - Herbert Falk
- File 09-0762-PBEngineeringFVD-Certificate.pdf added

Files

09-0762-PBEngineeringFVD-Certificate.pdf	553 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------