

IEC 61850 Certificate - IEC 61850 Certificate #1982

BCU 500 [EFACEC]

07/08/2021 04:20 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920376-Consulting 09-1001
61850 Edition:	Edition 1	Certificate Hash:	717BE10862D2A3907C497DDB53E9AC AF803F39D18E6AA059AEDC65CD4C0 79F9D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	EFACEC	Vendor Artifact Hash:	
Address:	Rua Eng. Frederico Ulrich, Guardedeiras 4470-605 Maia Portugal	Umbrella Organization:	
Product:	BCU 500	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/06/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 09-1001_EFACEC_BCU500_Certificate.pdf added

Files

09-1001_EFACEC_BCU500_Certificate.pdf

710 KB

07/08/2021

Herbert Falk