

# IEC 61850 Certificate - IEC 61850 Certificate #1983

## TPU S420 [EFACEC]

07/08/2021 04:20 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30920376-Consulting 09-1003
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	BAE005450DB1F57427E4D84032A7BB C315F80240C9D0C86F62D6A512C47A 8DB5
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	EFACEC	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Rua Eng. Frederico Ulrich, Guardedeiras 4470-605 MAIA Portugal	<b>Umbrella Organization:</b>	
<b>Product:</b>	TPU S420	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	Ed 1	<b>Serial Number:</b>	
<b>SW Version:</b>	7.3	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/06/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:20 PM - Herbert Falk

- File 09-1003\_EFACEC\_TPU\_S420\_Certificate.pdf added

### Files

09-1003_EFACEC_TPU_S420_Certificate.pdf	839 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------