

IEC 61850 Certificate - IEC 61850 Certificate #1985

Siprotec V4 7SJ80 Overcurrent [Siemens A.G., PTD EA]

07/08/2021 04:21 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	3082035-Consulting 09-1114
61850 Edition:	Edition 1	Certificate Hash:	DC4D663915F083217F157533E1A3335 9349432A80321D49B4E19DABB694E9 0CF
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens A.G., PTD EA	Vendor Artifact Hash:	
Address:	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	Umbrella Organization:	
Product:	Siprotec V4 7SJ80 Overcurrent	Optional Reservation Test:	No
HW Version:	EN100 V04.03	Serial Number:	
SW Version:	04.61	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/06/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1114_Siemens_7SJ80_Certificate.pdf added

Files

09-1114_Siemens_7SJ80_Certificate.pdf	779 KB	07/08/2021	Herbert Falk
---------------------------------------	--------	------------	--------------