

# IEC 61850 Certificate - IEC 61850 Certificate #1988

## Siprotec V4 7UT68 Differential [Siemens A.G., PTD EA]

07/08/2021 04:21 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30920444-Consulting 09-1120
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	AA9AE9E85A12BA32C88B422CB70F0 B8AD47B9AC990341D8ECFCBE5B87A B7098D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Siemens A.G., PTD EA	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Protection and Substation Control Systems Wernerwerkdamm 5 D-13623 Berlin Germany	<b>Umbrella Organization:</b>	
<b>Product:</b>	Siprotec V4 7UT68 Differential	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	EN100 V04.03	<b>Serial Number:</b>	
<b>SW Version:</b>	04.60	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Protection	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/08/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1120\_Siemens\_7UT68\_Certificate.pdf added

### Files

09-1120_Siemens_7UT68_Certificate.pdf	778 KB	07/08/2021	Herbert Falk
---------------------------------------	--------	------------	--------------