

IEC 61850 Certificate - IEC 61850 Certificate #1989

UDC-501 [SHR Automation]

07/08/2021 04:21 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920410-Consulting 09-1136
61850 Edition:	Edition 1	Certificate Hash:	942636FA2CC185FD376045CF9DB8D8 C53D9F0B56FA80E6B22756EF67AD8B 494E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SHR Automation	Vendor Artifact Hash:	
Address:	3399 Huaning Road Minhang District Shanghai 201108, China	Umbrella Organization:	
Product:	UDC-501	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R2.03	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/08/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1136-SHR-UDC-501-Certificate.pdf added

Files

09-1136-SHR-UDC-501-Certificate.pdf	698 KB	07/08/2021	Herbert Falk
-------------------------------------	--------	------------	--------------