

# IEC 61850 Certificate - IEC 61850 Certificate #1994

## MotorVision MVD [P&B Engineering]

07/08/2021 04:21 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30820234-Consulting 09-1524
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	C60ECFF481653BA044AFE33B2CC72 CE0BBB3CAA8DF7641D3661B7170602 CFDC0
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	P&B Engineering	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Belle Vue Works Boundary Street Manchester M12 5NG UK	<b>Umbrella Organization:</b>	
<b>Product:</b>	MotorVision MVD	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	2.058	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/08/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1524\_TXU\_Certificate\_for\_PB\_Eng\_MVD.pdf added

### Files

09-1524_TXU_Certificate_for_PB_Eng_MVD.pdf	1.09 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------