

IEC 61850 Certificate - IEC 61850 Certificate #1995

NS3500 UHV Measuring and Contr [NARI Group Corporation]

07/08/2021 04:21 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920409-Consulting 09-1642
61850 Edition:	Edition 1	Certificate Hash:	22D75757EF615B690338310CAE89FF4 46E23B6B10955FDF710FF5CB666A32 A51
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NARI Group Corporation	Vendor Artifact Hash:	
Address:	NO. 8 Nanrui Road Nanjing 210003, P.R. China	Umbrella Organization:	
Product:	NS3500 UHV Measuring and Contr	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	6.121	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/08/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1642_NARI_NS3500_Certificate.pdf added

Files

09-1642_NARI_NS3500_Certificate.pdf	446 KB	07/08/2021	Herbert Falk
-------------------------------------	--------	------------	--------------