

# IEC 61850 Certificate - IEC 61850 Certificate #1999

## REF615 [ABB Oy]

07/08/2021 04:21 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30920420-Consulting 09-1712
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	058D913211B2FF7F859F5717D6A885A FD2A7D41DD042EB90DFCF7549586A B1DE
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ABB Oy	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Distribution Automation Muottitie 2 A FI-65101 Vaasa Finland	<b>Umbrella Organization:</b>	
<b>Product:</b>	REF615	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	C	<b>Serial Number:</b>	
<b>SW Version:</b>	2.0.3	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/10/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1712\_ABB\_REF615-RED615-RET615-REM615\_Certificate.pdf added

### Files

09-1712_ABB_REF615-RED615-RET615-REM615_Certificate.pdf	478 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------