

IEC 61850 Certificate - IEC 61850 Certificate #2000

D25 Multifunction IED Gen 4 [GE Energy]

07/08/2021 04:21 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920394-Consulting 09-1748
61850 Edition:	Edition 1	Certificate Hash:	67365913AE9EC727A458AB4CB52293 034F755E9056EDFB9B7448EA397C93 B42A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Energy	Vendor Artifact Hash:	
Address:	2728 Hopewell Place NE, Calgary, AB T1Y 7J7 Canada	Umbrella Organization:	
Product:	D25 Multifunction IED Gen 4	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	3.00	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1748_GE_D25_Certificate.pdf added

Files

09-1748_GE_D25_Certificate.pdf	1.26 MB	07/08/2021	Herbert Falk
--------------------------------	---------	------------	--------------