

# IEC 61850 Certificate - IEC 61850 Certificate #2002

## Sepam series 80 [Schneider Electric]

07/08/2021 04:21 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30910052-Consulting 09-1834
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	154501288AF607830BCC6B1D19DEA7 A234A8E9054A9168092CF5434F8C111 3D5
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Power Monitoring & Control (PMC) Electropole - 38EQI 38050 GRENOBLE CEDEX 9 France	<b>Umbrella Organization:</b>	Schneider Electric
<b>Product:</b>	Sepam series 80	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	6.0	<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/10/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1834\_SJM\_Schneider\_Sepam\_series\_80\_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

09-1834_SJM_Schneider_Sepam_series_80_Certificate.pdf	837 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------