

IEC 61850 Certificate - IEC 61850 Certificate #2003

Sepam series 40 [Schneider Electric]

07/08/2021 04:21 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30910052-Consulting 09-1836
61850 Edition:	Edition 1	Certificate Hash:	1042D6B6E9EBBCEAC768E7631933E8 D6FF3B8FDA2CAF91A5558A3815AFA2 FFBE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric	Vendor Artifact Hash:	
Address:	Power Monitoring & Control (PMC) Electropole - 38EQI 38050 GRENOBLE CEDEX 9 France	Umbrella Organization:	Schneider Electric
Product:	Sepam series 40	Optional Reservation Test:	No
HW Version:	7.0	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-1836_SJM_Schneider_Sepam_series_40_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

09-1836_SJM_Schneider_Sepam_series_40_Certificate.pdf	838 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------