

IEC 61850 Certificate - IEC 61850 Certificate #2006

GRD140 [TOSHIBA Corporation]

07/08/2021 04:21 PM - Herbert Falk

| | | | |
|--|--|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 30920539-Consulting 09-2523 |
| 61850 Edition: | Edition 1 | Certificate Hash: | 1ACA7A333AE89BDD33876D65AB0801 8BEF421E2065A2B8B13613F91E5E995 174 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | TOSHIBA Corporation | Vendor Artifact Hash: | |
| Address: | Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-Shi, Tokyo, 183-8511 Japan | Umbrella Organization: | |
| Product: | GRD140 | Optional Reservation Test: | No |
| HW Version: | | Serial Number: | |
| SW Version: | GSPDM1-04-A | Publisher Legacy Variants: | |
| Key Words: | | Publisher Preferred Rates: | |
| Test Procedure Version: | 2.2 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | rebecca.davenport,kathy.ellis | Subscriber Preferred Variants: | |
| Approval Date: | 07/10/2015 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |
| Description | | | |
| This certificate and its information was migrated from a previous database | | | |

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-2523_Toshiba_GRD140_Certificate.pdf added

Files

| | | | |
|--|--------|------------|--------------|
| 09-2523_Toshiba_GRD140_Certificate.pdf | 710 KB | 07/08/2021 | Herbert Falk |
|--|--------|------------|--------------|