

IEC 61850 Certificate - IEC 61850 Certificate #2007

GRB100 [TOSHIBA Corporation]

07/08/2021 04:21 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920539-Consulting 09-2525
61850 Edition:	Edition 1	Certificate Hash:	B6769952C1F747E63740E8C4766A778 B5FF867AA2355889FA1DBCE4E1E986 A3C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	TOSHIBA Corporation	Vendor Artifact Hash:	
Address:	Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-Shi, Tokyo, 183-8511 Japan	Umbrella Organization:	
Product:	GRB100	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	GSPBM1-01-A	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-2525_Toshiba_GRB100_Certificate.pdf added

Files

09-2525_Toshiba_GRB100_Certificate.pdf	710 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------