

IEC 61850 Certificate - IEC 61850 Certificate #2008

PCT210 IEC-MMS-GOOSE [Advanced Control Systems]

07/08/2021 04:21 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920469-Consulting 09-2637
61850 Edition:	Edition 1	Certificate Hash:	55FAD4CB76F0A586AE87344785390F 633C0ABC404D16335FA7806507CDBD AE0C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Advanced Control Systems	Vendor Artifact Hash:	
Address:	Brankova 30 11000 Belgrade Serbia	Umbrella Organization:	
Product:	PCT210 IEC-MMS-GOOSE	Optional Reservation Test:	No
HW Version:	A01-002-000005	Serial Number:	
SW Version:	1.0.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 09-2637_ACS_PCT210_Certificate.pdf added

Files

09-2637_ACS_PCT210_Certificate.pdf

977 KB

07/08/2021

Herbert Falk