

IEC 61850 Certificate - IEC 61850 Certificate #2010

REC670 [ABB AB]

07/08/2021 04:21 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30920566-Consulting 10-0379
61850 Edition:	Edition 1	Certificate Hash:	BFC5471843DCA65E74D4F735E1855E6DED3A0ED6C7824ED082E7FC027B927B1F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB AB	Vendor Artifact Hash:	
Address:	SA Products S-721 59 Vasteras Sweden	Umbrella Organization:	
Product:	REC670	Optional Reservation Test:	No
HW Version:	1MRK001535-19	Serial Number:	
SW Version:	1.5.0.1	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:21 PM - Herbert Falk

- File 10-0379_ABB_REB670-REC670-RED670-REG670-REL670-RET670_Certificate.pdf added

Files

10-0379_ABB_REB670-REC670-RED670-REG670-REL670-RET670_Certificate.pdf 07/08/2021

Herbert Falk