

IEC 61850 Certificate - IEC 61850 Certificate #2013

PCS-902 [NR Electric Co., Ltd.]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30102065-Consulting 10-0989
61850 Edition:	Edition 1	Certificate Hash:	63B182912EEF7CC189081A669FF49C E87574C1CE0B1241079CD61B90B333 6A48
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NR Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 69 Suyuan Avenue Jiangning District, Nanjing City P.R. China, 211102	Umbrella Organization:	
Product:	PCS-902	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.01	Publisher Legacy Variants:	
Key Words:	Distance, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/10/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-0989_NR-E_PCS-902_Certificate.pdf added

Files

10-0989_NR-E_PCS-902_Certificate.pdf	572 KB	07/08/2021	Herbert Falk
--------------------------------------	--------	------------	--------------