IEC 61850 Certificate - IEC 61850 Certificate #2015

Distance Relay MDT-HA [Mitsubishi Electric Corporation]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30920532-Consulting 10-1051
61850 Tested Aspects:	Server	**Certificate Hash:**	9D61CC115066BAC51DF637DDC7746 0C77EE4BA5FDACA39E34B4DB14270 C354DB
Company:	Mitsubishi Electric Corporation	**Vendor Artifact File Name:**	
Address:	Protection & Control Systems Transmission & Distribution Systems Center Kobe, Japan	**Vendor Artifact Hash:**	
Product:	Distance Relay MDT-HA	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	MM-CPU PGHN11A/MR-CPU PGHN12F	**Serial Number:**	
Key Words:	Distance, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	2.2	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	07/11/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-1051_Mitsubishi_MDT-HA_Certificate.pdf added

Files

10-1051_Mitsubishi_MDT-HA_Certificate.pdf	484 KB	07/08/2021	Herbert Falk