

IEC 61850 Certificate - IEC 61850 Certificate #2016

YSDPI9800 Multifunction Prot. [YOUSUNG Instrument & Electric Co., Ltd.]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30102113-Consulting 10-1576
61850 Edition:	Edition 1	Certificate Hash:	46F69BACAC3E1DC26CF098D6942749 5277D635D3A5789025E909D5C5251E A93F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	YOUSUNG Instrument & Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	#7-13, SONGDO-DONG, YEONSU-GU INCHEON-CITY, 406-840 Republic of Korea	Umbrella Organization:	
Product:	YSDPI9800 Multifunction Prot.	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/11/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-1576_Yousung_YSDPI9800_Certificate.pdf added

Files

10-1576_Yousung_YSDPI9800_Certificate.pdf	480 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------