

IEC 61850 Certificate - IEC 61850 Certificate #2017

GRB150 [TOSHIBA Corporation]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30102109-Consulting 10-1616
61850 Edition:	Edition 1	Certificate Hash:	0B947BDC0F9DCE3BE23A909B0EA6D FAE543D4AA19F0E4D8B01505F28FF9 BE559
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	TOSHIBA Corporation	Vendor Artifact Hash:	
Address:	Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-Shi, Tokyo, 183-8511 Japan	Umbrella Organization:	
Product:	GRB150	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	GSPBP1-01-A	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/11/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-1616_Toshiba_GRB150_Certificate.pdf added

Files

10-1616_Toshiba_GRB150_Certificate.pdf	507 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------