IEC 61850 Certificate - IEC 61850 Certificate #2018

GRD130 [TOSHIBA Corporation]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30102109-Consulting 10-1617
61850 Tested Aspects:	Server	**Certificate Hash:**	5A516F9ADB8A56D1D68FB92E3B152800804818A3657613790E57D98DB7F95989
Company:	TOSHIBA Corporation	**Vendor Artifact File Name:**	
Address:	Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-Shi, Tokyo, 183-8511 Japan	**Vendor Artifact Hash:**	
Product:	GRD130	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	GSPDM1-03-A	**Serial Number:**	
Key Words:		**Publisher Legacy Variants:**	
Test Procedure Version:	2.2	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	07/12/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-1617_Toshiba_GRD130_Certificate.pdf added

Files

10-1617_Toshiba_GRD130_Certificate.pdf	501 KB	07/08/2021	Herbert Falk