

# IEC 61850 Certificate - IEC 61850 Certificate #2019

## GRD110 [TOSHIBA Corporation]

07/08/2021 04:22 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30102109-Consulting 10-1620
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	384BCD8160B7A18A077B7201474F624 38AC5C3E10D723C4C5320199C71EE5 C03
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	TOSHIBA Corporation	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-Shi, Tokyo, 183-8511 Japan	<b>Umbrella Organization:</b>	
<b>Product:</b>	GRD110	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	GSPDM1-01-A	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/12/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-1620\_Toshiba\_GRD110\_Certificate.pdf added

### Files

10-1620_Toshiba_GRD110_Certificate.pdf	506 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------