

IEC 61850 Certificate - IEC 61850 Certificate #2022

PCS-931 Line Diff Relay [NR Electric Co., Ltd.]

07/08/2021 04:22 PM - Herbert Falk

| | | | |
|-------------------------------------|--|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 30102065-Consulting 10-1892 |
| 61850 Edition: | Edition 1 | Certificate Hash: | BB8AFCD5F6EC13116CBF4003FDD33 E8028B61081806DA46A45058711E3AD FD30 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | NR Electric Co., Ltd. | Vendor Artifact Hash: | |
| Address: | No. 69 Suyuan Avenue Jiangning District, Nanjing City P.R. China, 211102 | Umbrella Organization: | |
| Product: | PCS-931 Line Diff Relay | Optional Reservation Test: | No |
| HW Version: | PCS-900-HW-V1.06 | Serial Number: | |
| SW Version: | PCS-900-SW-V2.12 | Publisher Legacy Variants: | |
| Key Words: | Differential, Relay | Publisher Preferred Rates: | |
| Test Procedure Version: | 2.2 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | rebecca.davenport,kathy.ellis | Subscriber Preferred Variants: | |
| Approval Date: | 07/12/2015 | | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-1892_NR_PCS-931_Certificate.pdf added

Files

| | | | |
|------------------------------------|--------|------------|--------------|
| 10-1892_NR_PCS-931_Certificate.pdf | 490 KB | 07/08/2021 | Herbert Falk |
|------------------------------------|--------|------------|--------------|