

# IEC 61850 Certificate - IEC 61850 Certificate #2024

## BE1-11 [Basler Electric]

07/08/2021 04:22 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30107058-Consulting 10-2026
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	6A3C4F41E4F0B09E337E939E20546C 790FA7CEB6B83F89CD39E45C97FC32 6198
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Basler Electric	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	12570 State Route 143 Highland IL 62249-0269 USA	<b>Umbrella Organization:</b>	
<b>Product:</b>	BE1-11	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	BE1-11-F5A1N5H1N0E00	<b>Serial Number:</b>	
<b>SW Version:</b>	2.04.00	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/14/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-2026\_Basler\_BE1\_11\_Certificate.pdf added

### Files

10-2026_Basler_BE1_11_Certificate.pdf	502 KB	07/08/2021	Herbert Falk
---------------------------------------	--------	------------	--------------