

IEC 61850 Certificate - IEC 61850 Certificate #2028

SPRECON-E-C Control Unit [Sprecher Automation GmbH]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30102175-Consulting 10-2528
61850 Edition:	Edition 1	Certificate Hash:	2B4951E7A4BD70DC2EB68B03DD159 F964C092BA5E819552B7B9266F5CB8 80078
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sprecher Automation GmbH	Vendor Artifact Hash:	
Address:	Franckstrasse 51 A-4018 Linz Austria	Umbrella Organization:	
Product:	SPRECON-E-C Control Unit	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	8.15	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/14/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-2528_Sprecher_SPRECON-E-C_Certificate.pdf added

Files

10-2528_Sprecher_SPRECON-E-C_Certificate.pdf	1.78 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------