

# IEC 61850 Certificate - IEC 61850 Certificate #2029

## PACiS GTW [Schneider Electric]

07/08/2021 04:22 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30920553-Consulting 10-2648
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	34284381BF732CC3EF9E71D9C62324 66E95542082CF259E4E46748AF53F29 F16
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Avenue de Figuières 34975 Lattes - France	<b>Umbrella Organization:</b>	Schneider Electric
<b>Product:</b>	PACiS GTW	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	6.2.16.3	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	07/14/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 10-2648\_Certificate\_Schneider\_Electric\_PACiS\_GTW.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

10-2648_Certificate_Schneider_Electric_PACiS_GTW.pdf	314 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------