

IEC 61850 Certificate - IEC 61850 Certificate #2030

RightWON System [Vizimax Inc.]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30107071-Consulting 11-0186
61850 Edition:	Edition 1	Certificate Hash:	127D41761A21FD7A56458D7EBF3DCE CAAACE30F9E8E7820BC8687F392A60 F886
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Vizimax Inc.	Vendor Artifact Hash:	
Address:	2284, rue de la Province Longueuil (Quebec) J4G 1G1 Canada	Umbrella Organization:	
Product:	RightWON System	Optional Reservation Test:	No
HW Version:	1.04	Serial Number:	
SW Version:	1.4.1	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/14/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 11-0186_Vizimax_RightWON_Certificate.pdf added

Files

11-0186_Vizimax_RightWON_Certificate.pdf	324 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------