

IEC 61850 Certificate - IEC 61850 Certificate #2032

SEL-751A Feeder Prot. Relay [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100372-MOC/INC 11-0372
61850 Edition:	Edition 1	Certificate Hash:	A05F5FF710ADADC61D248EBEBBBD7 E83989EA038BE6CC655B704B6C9509 E50A8
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	Umbrella Organization:	
Product:	SEL-751A Feeder Prot. Relay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R410	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/14/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 11-0372_SEL_751A_Certificate.pdf added

Files

11-0372_SEL_751A_Certificate.pdf

789 KB

07/08/2021

Herbert Falk