

IEC 61850 Certificate - IEC 61850 Certificate #2033

WebCAN Substation Control [SystemCORP Embedded Technology Pty Ltd.]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100344-MOC/INC 11-0597
61850 Edition:	Edition 1	Certificate Hash:	BC8FE269888B29879C3B269F38CBBF 3E1D585A56C1B9BE2D574CE0FA7E6 A8343
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SystemCORP Embedded Technology Pty Ltd.	Vendor Artifact Hash:	
Address:	Suite 4/12 Brodie Hall Drive Technology Park Bentley, WA 6102 Australia	Umbrella Organization:	
Product:	WebCAN Substation Control	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.36.00	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/14/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 11-0597_SystemCORP_WebCAN_Certificate.pdf added

Files

11-0597_SystemCORP_WebCAN_Certificate.pdf	424 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------