

IEC 61850 Certificate - IEC 61850 Certificate #2035

MFR-H1SA [Mitsubishi Electric Corporation]

07/08/2021 04:22 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100295-MOC/INC 11-0904
61850 Edition:	Edition 1	Certificate Hash:	C6A36B9D1B0456F69B03C7D4F1ED38 7A8D79F01505C46AEBFE652F36E286 5138
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	Protection & Control Systems Transmission & Distribution Systems Center Kobe, Japan	Umbrella Organization:	
Product:	MFR-H1SA	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	HL01B/HL02B/HL05/HL06A/HL08A	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/15/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:22 PM - Herbert Falk

- File 11-0904_Mitsubishi_MFR-H1SA_Certificate.pdf added

Files

11-0904_Mitsubishi_MFR-H1SA_Certificate.pdf	534 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------