

IEC 61850 Certificate - IEC 61850 Certificate #2037

ALSTOM GRID MiCOM P145 [ALSTOM GRID UK Ltd.]

07/08/2021 04:23 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100457-MOC/INC 11-1063
61850 Edition:	Edition 1	Certificate Hash:	5A783A5F5D1ABE761106C8AAA4F5C5 33860E132A6C0AB9FBCCE76FB55B5 B0AFD
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ALSTOM GRID UK Ltd.	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford ST17 4LX United Kingdom	Umbrella Organization:	
Product:	ALSTOM GRID MiCOM P145	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	46A	Publisher Legacy Variants:	
Key Words:	Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	07/15/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:23 PM - Herbert Falk

- File 11-1063_Alstom_Grid_MiCOM_P145_Certificate.pdf added

Files

11-1063_Alstom_Grid_MiCOM_P145_Certificate.pdf	551 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------